

Government of West Bengal
Office of the Executive Engineer
Birbhum Division, P.H.Engineering Dte.
P.H.E. Dte. Complex, S.P. More, Suni, Birbhum.
THE DISTRICT WATER TESTING LABORATORY

Quality Parameters				pH	Iron(Fe)	Fluoride	Hardness	Turbidity	TDS	Manganese	T.C	F.C	
Unit of Measurement				N/A	mg/l	mg/l	mg/l	NTU	mg/l	mg/l	CFU/ 100ml	CFU/ 100ml	
BIS Permissible Limit				8.5	1	1.5	600	5	2000	0.3	0	0	
BIS Desirable Limit				6.5	0.3	1.0	200	1	500	0.1	0	0	
Sl. No	Water Source Location	Reference (if any)	Date of Collection	Test Completion Date	pH	Iron (mg/l)	Fluoride (mg/l)	Hardness (mg/l)	Turbidity NTU	TDS (mg/l)	Manganese (mg/l)	T.C CFU/100ml	F.C CFU/100ml
1	GURUKUL PUBLIC SCHOOL, (PLOT NO- 17,18,19,23,24) KUTIGRAM MORE, NH-60 PO. & PS:- RAMPURHAT, G.P:- DAKHLBATI, BLOCK:- RAMPURHAT-I, BIRBHUM, 731234. DEPTH- 400 ft., DIA- 4 inch		17.12.2021	20.12.2021	6.57	0.1	0.05	110	0.81	40	0.002	0	0

Bacteriologist
Birbhum Division
P.H.E. Dte



Chemist
Birbhum Division
P.H.E. Dte



Junior Engineer
Birbhum Division
P.H.E. Dte



Assistant Engineer (RWS)
Birbhum Sub-Division
P.H.E. Dte



Bacteriologist
Birbhum Division
P.H.E. Dte

Disinfectant Laboratory
Birbhum Division, P.H.E. Dte
Sub-Division

Assistant Engineer
Birbhum Sub-Division
P.H.E. Dte

Assistant Engineer
R.W.S Birbhum Sub-Division
P.H.E. Dte


Bacteriologist
Birbhum Division
P.H.E. Dte.
Birbhum Division
PHE Dte.


Chemist
Birbhum Division
P.H.E. Dte.
District Water Laboratory
Birbhum Division, P.H.E. Dte.
Suni, Birbhum


Junior Engineer
Birbhum Division
P.H.E. Dte.
Birbhum Division, P.H.E. Dte.
Suni, Birbhum


Assistant Engineer (RWS)
Birbhum Sub-Division
Birbhum Division
P.H.E. Dte.
Assistant Engineer
R.W.S Birbhum Sub-Division
PHE Dte