

Government of West Bengal  
Office of the Executive Engineer  
Birbhum Division, P.H.Engineering Dte.  
P.H.E. Dte. Complex, S.P. More, Suri, Birbhum.  
**THE DISTRICT WATER TESTING LABORATORY**

Quality Parameters	pH	Iron(Fe)	Fluoride	Hardness	Turbidity	TDS	Manganese	T.C	F.C
Unit of Measurement	N/A	mg/l	mg/l	mg/l	NTU	mg/l	mg/l	CFU/ 100ml	CFU/ 100ml
BIS Permissible Limit	8.5	1	1.5	600	5	2000	0.3	0	0
BIS Desirable Limit	6.5	0.3	1.0	200	1	500	0.1	0	0

Sl. No	Water Source Location	Reference (if any)	Date of Collection	Test Completion Date	pH	Iron (mg/l)	Fluoride (mg/l)	Hardness (mg/l)	Turbidity NTU	TDS (mg/l)	Manganese (mg/l)	T.C CFU/100ml	F.C CFU/100ml
1	GURUKUL PUBLIC SCHOOL (PLOT NO- 17,18,19,23,24) KUTIGRAM MORE, NH-60 PO. & PS:- RAMPURHAT, G.P:- DAKHLBATI, BLOCK:- RAMPURHAT-I, BIRBHUM, 731234. DEPTH- 400 ft., DIA- 4 inch		17.12.2021	20.12.2021	6.57	0.1	0.05	110	0.81	40	0.002	0	0



Bacteriologist  
Birbhum Division  
P.H.E. Dte  
**Bacteriologist**  
Birbhum Division  
PHE Dte.



Chemist  
Birbhum Division  
P.H.E. Dte  
District W.T. Laboratory  
Birbhum Division, P.H.E Dte  
Sur, Birbhum



Junior Engineer  
Birbhum Division  
P.H.E Dte  
Birbhum Division, P.H.E Dte  
Suri, Birbhum



Assistant Engineer (RWS)  
Birbhum Sub-Division  
Birbhum Division  
P.H.E Dte.  
Assistant Engineer  
R.W.S Birb-Sub-Division  
PHE Dte.